## **NOTICE OF PRODUCT CERTIFICATION**

| CERTIFICATION NO: NI011300.03-R2<br>DATE: 10/05/2012<br>CERTIFICATION PROGRAM: Structural<br>COMPANY: Skyline<br>CODE: 1894-1<br>REVISION DATE: 10/28/2021 |
|--|
|--|

To verify that the "Notice of Product Certification" is valid, please visit <u>www.NAMICertification.com</u> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS   | <b>PRODUCT DESCRIPTION</b>   |
|----------------------------|--|
| Skyline Sky-Lites, LLC     | <b>"YPCMD-2852"</b>  |
| 2925 Delta Drive           | Vinyl Plastic Glazed Skylight  |
| Colorado Springs, CO 80910 |  |
|                            | Outer Pyramid: 0.111" Thick Cast Acrylic<br>Inner Pyramid: 0.111" Thick Cast Acrylic |
|                            | Frame: W-692mm(27.25") H-1302mm(51.25")  |
|                            | DLO: W-572mm(22.5") H-1181mm(46.5")  |

| SPECIFICATION                   | PRODUCT RATING  |
|---------------------------------|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 | PG100 692 x 1302 (27 x 51)-SKP<br>Design Pressure: 4800 Pa (100 psf)<br>Water Penetration Resistance Test Pressure: 580 (12.11 psf) |

Product Tested By: Report No: Expiration Date: Architectural Testing, Inc. C0180.01-801-47 June 30, 2024

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Fax: (804) 684-5122