

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011301.02-R2
DATE: 10/05/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Skyline
CODE: 1894-1
REVISION DATE: 10/28/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Skyline Sky-Lites, LLC 2925 Delta Drive Colorado Springs, CO 80910	"VEN-TFCMD 5276" Thermally Broken Aluminum Glass Glazed Roof Window Glazing: IG-1/8" Tempered Glass/ 1/8" Heat Strengthened Glass/0.060" PVB Interlayer/ 1/8" Heat Strengthened Glass Frame: W-1321mm(52") H-1905mm(75") DLO: W-1181mm(46.5") H-1772mm(69.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	PG30 1321 x 1905 (52 x 75)-RWG Design Pressure: 1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 580 (12.11 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C0188.01-801-47
Expiration Date: June 30, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shelby", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122