

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011315.01-R3  
**DATE:** 11/08/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Loewen  
**CODE:** 1862-1  
**REVISION DATE:** 09/14/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Loewen</b>  <b>77 Highway 52 West</b>  <b>Steinbach, Manitoba R5G 1B2</b>	<b>“Clad Wood Patio”</b>  <b>Aluminum Clad Wood Sliding Glass Door</b>  <b>w/Impact Glazing</b>  Configuration: XO Glazing: IG-4mm Tempered Glass (Exterior)/Laminate- 3.1mm Annealed Glass/2.3mm SentryGlas Plus Interlayer/ 3.1mm Annealed Glass (Interior)  Frame: W-2400mm(94.5") H-2400mm(94.5")  Panel: W-1208mm(47.57") H-2349mm(91.5")  DLO: W-1060mm(41.75") H-2165mm(85.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>ASTM E1886-02/05/E1996-02/05</b> <b>TAS 201/202-203-94</b>	<b>LC-PG55 2400 x 2400 (94 x 94)–SD</b> <b>SD-LC55 2400 x 2400 (94 x 94)</b> <b>Design Pressure: +55/-55 psf</b> Water Penetration Resistance Test Pressure: 510 Pa (10.5 psf) <b>Wind Zone 4-Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Architectural Testing, Inc.  
 Report No: 89339.01-201-44/89339.02-201-44/89339.03-201-44  
 Expiration Date: **October 31, 2033**

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)