

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011326-R5
DATE: 10/26/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Hoelscher
CODE: 1765-1
REVISION DATE: 06/20/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hoelscher Weatherstrip Manufacturing Company, Inc. 2400 S. Persimmon Street Tomball, TX 77375	Series "3080" Full Lite Glazed Fiberglass Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-956mm(37.63") H-2483mm(97.75") Panel: W-914mm(36") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
ASTM E330-02	Design Pressure: 2633 Pa (55 psf) Negative Design Pressure: 2633 Pa (55 psf)

Product Tested By: Architectural Testing, Inc.
Report No: B6930.01-801-44
Expiration Date: June 30, 2026

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023