

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011350.16-R8  
DATE: 04/22/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 07/25/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> 433 North Main Street Rocky Mount, VA 24151	<b>"Ply Gem 1500"</b> <b>Vinyl Tilt Single Hung Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1346mm(53") H-1959mm(77.13") Sash: W-1279mm(50.38") H-954mm(37.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	<b>Class LC-PG40 1346 x 1959 (53 x 77)-H</b> <b>H-LC40 1346 x 1959 (53 x 77)</b> <b>Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-16029-1/110-15597-1/W-1717/W-1758/W-1831/W-1867/  
W-2047/W-2112/W-2125  
Expiration Date: **March 31, 2027**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)