

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011370-R5  
**DATE:** 12/20/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Dunbarton  
**CODE:** 1319-1  
**REVISION DATE:** 07/12/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Dunbarton Corporation</b> <b>555 Benton Industrial Road</b> <b>Camden, TN 38320</b>	<b>Series "Achiever Frame System"</b> <b>Fixed Full Lite Fiberglass Sidelite</b> <b>w/Steel Frame</b>  Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-407mm(16.00") H-2115mm(83.25") Panel: W-302mm(11.88") H-2013mm(79.25") DLO: W-153mm(6.00") H-1604mm(63.13") STP: Pos+5028 Pa (105.00 psf) Neg-5028 Pa (105.00 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01090356-A  
Expiration Date: May 31, 2024

Administrator's Signature: 

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)