

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011373-R5  
DATE: 12/20/2012  
CERTIFICATION PROGRAM: Structural  
COMPANY: Dunbarton  
CODE: 1319-1  
REVISION DATE: 07/12/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Dunbarton Corporation</b> <b>555 Benton Industrial Road</b> <b>Camden, TN 38320</b>	<b>Series "Achiever Frame System"</b> <b>In-Swing Opaque VC Steel Door</b> <b>w/Sidelites &amp; Steel Frame</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-1702mm(67.00") H-2115mm(83.25") Panel: W-909mm(35.75") H-2013mm(79.25") DLO: W-150mm(5.88") H-1598mm(62.88") STP: Pos+4022 Pa (84.00 psf) Neg-4022 Pa (84.00 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01090356  
Expiration Date: May 31, 2024

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S.M.D.", is written over the signature line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)