

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011375-R4
DATE: 12/20/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Dunbarton
CODE: 1319-1
REVISION DATE: 08/10/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dunbarton Corporation 555 Benton Industrial Road Camden, TN 38320	Series "Achiever Frame System" In-Swing Full Lite VC Steel Door w/Steel Frame Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1020mm(40.12") H-2115mm(83.25") Panel: W-909mm(35.75") H-2013mm(79.25") DLO: W-537mm(21.13") H-1604mm(63.13") STP: Pos+3232 Pa (67.50 psf) Neg-3591 Pa (75.00 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.305	Manufactured Housing-Passed Wind Zone III

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01090357
Expiration Date: May 31, 2022

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.H.D.", is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122