

# NOTICE OF PRODUCT CERTIFICATION




**CERTIFICATION NO:** NI011380-R5  
**DATE:** 01/02/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nabco  
**CODE:** 1937-1  
**REVISION DATE:** 09/13/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION  |
|--|--|
| <b>Nabco Entrances, Inc.</b><br><b>S82 W18717 Gemini Drive</b><br><b>Muskego, WI 53150</b> | <b>Series "GT 1175"</b><br><b>Glazed Bipart Aluminum Slider</b><br><b>Fixed Sidelite w/o Transom</b><br><br>Configuration: OXXO<br>Glazing: Laminate-3/16" Tempered Glass/<br>1/8" Solutia Saflex Interlayer/3/16" Tempered Glass<br><br>Frame: W-4877mm(192") H-2324mm(91.5")<br>Panel: W-1240mm(48.81") H-2115mm(83.25") |

| SPECIFICATION             | PRODUCT RATING   |
|---------------------------|--|
| <b>TAS 201/202/203-94</b> | <b>Design Pressure: +60/-60 psf</b><br><b>Large &amp; Small Missile Impact Rated</b> |

Product Tested By: Hurricane Engineering & Testing, Inc./Architectural Testing, Inc.  
Report No: HETI-00-888/HETI-00-891/HETI-00-4166/HETI-00-T051/ATI-C2942.01-602-18/W-1537  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)