

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011395.05-R8  
**DATE:** 01/10/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 07/25/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>"Ply Gem 1500"</b> <b>Vinyl Tilt Single Hung Window</b> <b>Integral Mull Triple</b>  Configuration: XOX Glazing: Insulating Glass (Annealed)  Frame: W-3075mm(121.06") H-1957mm(77.06") Sash: W-953mm(37.5") H-954mm(37.56")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>CSA A440S1-09</b>	<b>Class LC-PG45 3075 x 1957 (121 x 77)-H</b> <b>H-LC45 3075 x 1957 (121 x 77)</b> <b>Design Pressure: 2160 Pa (45 psf)</b> <b>Negative Design Pressure: 2160 Pa (45 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level = A2</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15644-1/NCTL-110-15645-1/W-1717/W-1758/W-1867/W-2112/W-2125  
Expiration Date: November 30, 2026

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)