

# NOTICE OF PRODUCT CERTIFICATION



<b>CERTIFICATION NO:</b>	<u>NI011395.24-R2</u>
<b>DATE:</b>	<u>01/03/2014</u>
<b>CERTIFICATION PROGRAM:</b>	<u>Structural</u>
<b>COMPANY:</b>	<u>Ply Gem</u>
<b>CODE:</b>	<u>1408-1</u>
<b>REVISION DATE:</b>	<u>02/03/2022</u>

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b></p>	<p style="text-align: center;"><b>"Ply Gem 1500" Vinyl Collection</b> <b>Vinyl Tilt Single Hung Window</b></p> <p style="text-align: center;">Configuration: O/X Glazing: IG-1/8" Annealed Glass (Exterior)/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass (Interior)</p> <p>Frame: W-2029mm(79.88")    H-1826mm(71.88") Sash: W-941mm(37.06")    H-885mm(34.88")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;"><b>AAMA 506-06/08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>CSA A440S1-09</b> <b>ASTM E1886-02/05/E1996-02/05</b></p>	<p style="text-align: center;"><b>Overall Design Pressure: +50/-60 psf</b> <b>Wind Zone 3-Missile Level D</b> <b>Class LC-PG50 2029 x 1826 (80 x 72)-H</b> <b>H-LC50 2029 x 1826 (80 x 72)</b> <b>Negative Design Pressure: 2880 Pa (60 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A2</b></p>

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-110-1667-1/NCTL-15641-1/NCTL-110-15642-1  
 Expiration Date: **October 31, 2026**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)