

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011405-R6
DATE: 01/21/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 06/15/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151 | "Ply Gem 1500" Vinyl Horizontal Sliding Window Configuration: OX Glazing: Insulating Glass (Annealed) Frame: W-1827mm(71.94") H-1829mm(72") Panel: W-879mm(34.62") H-1759mm(69.25") STP: Pos+1190 Pa (25 psf) Neg-595 Pa (12.5 psf) |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA 1701.2-95/AAMA 1701.2-02 Federal Manufactured Home Construction & Safety Standard 3280.305 AAMA 1704-85/01 | Manufactured Housing-Passed Wind Zone I Design Wind Pressure Rating: +25/-12.5 psf Egress-Passed |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15628-2/W-1831/W-1867
Expiration Date: **October 31, 2024**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com