

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011430-R4
DATE: 02/05/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Orepac
CODE: 1234-1
REVISION DATE: 01/24/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
OrePac Building Products 30160 SW Orepac Avenue Wilsonville, OR 97070	Series "OXO 8/0 Opaque Composite" Opaque In-Swing Fiberglass Side-Hinged Door w/Fixed Sidelites & Composite Frame Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1740mm(68.50") H-2478mm(97.57") Panel: W-910mm(35.82") H-2420mm(95.25") DLO: W-180mm(7.00") H-2010mm(79.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R PG35 1740 x 2478 (69 x 98)-LW Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1680 Pa (35 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Architectural Testing Incorporated
Report No: C3028.01-901-44
Expiration Date: **January 31, 2024**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com