NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI011430.01-R7

DATE: 02/05/2013

CERTIFICATION PROGRAM: Structural

COMPANY: Orepac

CODE: 1234-1

REVISION DATE: 10/25/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
OrePac Building Products	Series "OXO 8/0 Opaque Composite"		
30160 SW Orepac Avenue	Opaque In-Swing Fiberglass Side-Hinged		
Wilsonville, OR 97070	Door w/Fixed Sidelites & Composite		
	Frame		
		Configuration: Glazing: Insulating Glass	
	Frame:	W-1740mm(68.5")	H-2478mm(97.57")
	Panel:	W-910mm(35.82")	H-2420mm(95.25")
	STP:	Pos+2777 Pa (58 psf) N	Neg-2777 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.02-95/02 Federal Manufactured Home Construction & Safety Standard 3280.405(e)	Manufactured Housing-Passed Wind Zone III

Product Tested By: Architectural Testing Incorporated

Report No: C3028.02-901-44 Expiration Date: **January 31, 2026**

Administrator's Signature:___

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023