

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011431.01-R9
DATE: 02/05/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Orepac
CODE: 1234-1
REVISION DATE: 12/15/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
OrePac Building Products 30160 SW Orepac Avenue Wilsonville, OR 97070	Series "OXO Glazed Wood" Glazed In-Swing Fiberglass Side-Hinged Door w/Fixed & Direct Sidelites & Wood Frame Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1738mm(68.44") H-2070mm(81.5") Panel: W-910mm(35.82") H-2008mm(79") STP: Pos+2777 Pa (58 psf) Neg-2777 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-12 Federal Manufactured Home Construction & Safety Standard 3280.405(e)	Manufactured Housing-Passed Wind Zone III

Product Tested By: Architectural Testing Incorporated
Report No: C3023.02-901-44/W-2148
Expiration Date: **January 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023