

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011432.01-R7  
DATE: 02/06/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: Orepac  
CODE: 1234-1  
REVISION DATE: 10/25/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>OrePac Building Products</b> <b>30160 SW Orepac Avenue</b> <b>Wilsonville, OR 97070</b>	<b>Series "XX 6/8 Double Door Composite Frame" Glazed In-Swing Fiberglass Side-Hinged Door &amp; Composite Frame</b>  Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1890mm(74.44") H-2070mm(81.5") Panel: W-910mm(35.82") H-2008mm(79") STP: Pos+2777 Pa (58 psf) Neg-2777 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.02-95/02</b> <b>Federal Manufactured Home Construction &amp; Safety Standard 3280.405(e)</b>	<b>Manufactured Housing-Passed Wind Zone III</b>

Product Tested By: Architectural Testing Incorporated  
Report No: C3025.02-901-44  
Expiration Date: January 31, 2026

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023