

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011433-R7
DATE: 02/05/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Orepac
CODE: 1234-1
REVISION DATE: 01/30/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
OrePac Building Products 30160 SW Orepac Avenue Wilsonville, OR 97070	Series "OXO Opaque Composite" Opaque In-Swing Fiberglass Side-Hinged Door w/Fixed & Direct Set Sidelites & Composite Frame Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1738mm(68.44") H-2073mm(81.63") Panel: W-910mm(35.82") H-2008mm(79.00") Sidelite: W-390mm(15.69") H-2008mm(79.00") DLO: W-325mm(12.82") H-1995mm(78.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R PG35 1738 x 2073 (69 x 82)-LW Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1680 Pa (35 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Architectural Testing Incorporated
Report No: C3024.01-901-44/W-2180
Expiration Date: **January 31, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023