

# NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI011433.01-R9  
DATE: 02/06/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: Orepac  
CODE: 1234-1  
REVISION DATE: 12/15/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>OrePac Building Products</b> <b>30160 SW Orepac Avenue</b> <b>Wilsonville, OR 97070</b>	<b>Series "OXO Opaque Composite"</b> <b>Opaque In-Swing Fiberglass Side-Hinged</b> <b>Door w/Fixed &amp; Direct Set Sidelites</b> <b>&amp; Composite Frame</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-1738mm(68.44") H-2073mm(81.63") Panel: W-910mm(35.82") H-2008mm(79") Sidelite: W-390mm(15.69") H-2008mm(79") DLO: W-325mm(12.82") H-1995mm(78.5") STP: Pos+2777 Pa (58 psf) Neg-2777 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-12</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.405(e)</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b>

Product Tested By: Architectural Testing Incorporated  
Report No: C3024.02-901-44/W-2148  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023