

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011439.01-R4
DATE: 02/09/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1
REVISION DATE: 12/03/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, VA 26104	Series "8800" Impact Resistant Vinyl Horizontal Sliding Window Configuration: XOX Glazing: IG-Laminate-1/8" Annealed Glass/ 0.090" Solutia Interlayer/1/8" Annealed Glass/ 1/8" Annealed Glass Frame: W-2794mm(110") H-1575mm(62") DLO: W-883mm(32.43") H-1372mm(54")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/13a/E1996-06/14a	Class LC-PG55 2794 x 1575 (110 x 62)-HS Design Pressure: 2633 Pa (55 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure = 467 Pa (9.75 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02800537 Rev 1/TEL 02800538/V-201016/W-1920
Expiration Date: December 31, 2029

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023