

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011484-R3
DATE: 03/05/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Solar
CODE: 872-1
REVISION DATE: 11/12/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Solar Innovations, Inc. 31 Roberts Road Pine Grove, PA 17963	Series "SI3000 FGW 3 x 8 Panel" Out-Fold Aluminum Folding Glass Wall w/Panic Hardware Configuration: XXXXXX Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Annealed Glass/0.090"DUPONT Sentry Glass Plus Interlayer/3/16" Annealed Glass Frame: W-5665mm (223.00") H-2553mm (100.50") Panel: W-915mm (36.00") H-2439mm (96.00") DLO: W-737mm (29.00") H-2261mm (89.00")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/ASTM E330-02(10)/ ASTM E331-00(09)	Design Pressure: 3112 Pa (65.0 psf) Negative Design Pressure: 3112 Pa (65.0 psf) Water Penetration Resistance Test Pressure: 575 Pa (12.0 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-110-15135-2
Expiration Date: **July 31, 2031**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com