

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011487.02-R3  
**DATE:** 03/05/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Solar  
**CODE:** 872-1  
**REVISION DATE:** 04/10/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Solar Innovations, Inc.</b> <b>31 Roberts Road</b> <b>Pine Grove, PA 17963</b>	<b>Series "SI3000" Standard and</b> <b>"Lite Rail" In-Fold and Out-Fold</b> <b>Aluminum Folding Glass Wall</b>  Configuration: XXX/XXX Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Annealed Glass/0.090"Dupont Sentry Glass Plus Interlayer/3/16"Annealed Glass  Frame: W-6622mm (260.69") H-3010mm (118.50") Panel: W-1067mm (42.00") H-2896mm (114.00") DLO: W-997mm (39.25") H-2725mm (107.25")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04(12)/ASTM E330-02(10)/</b> <b>ASTM E331-00(09)</b>	<b>Design Pressure: 2394 Pa (50.0 psf)</b> <b>Negative Design Pressure: 2394 Pa (50.0 psf)</b> <b>Water Penetration Resistance Test Pressure: 575 Pa (12.0 psf)</b>

Product Tested By: National Certified Testing Laboratories, Inc.  
Report No: NCTL-110-15327-2  
Expiration Date: **September 30, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023