NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011489-R10**
DATE:	**03/06/2013**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**
REVISION DATE:	**07/21/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**Series "Contours Steel (S-2500)** **Wood Edge"** **Steel Glazed Side Hinged Door** Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-953mm(37.50") H-2052mm(80.75") Panel: W-909mm(35.75") H-2013mm(79.25") DLO: W-499mm(19.63") H-397mm(15.63")

SPECIFICATION	PRODUCT RATING
TAS 202-94	**Design Pressure: 2634 Pa (55 psf)** **Negative Design Pressure: 2634 Pa (55 psf)** **Water Penetration Resistance Test Pressure: 396 Pa (8.25 psf)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3857-1/A009078/W-1897/W-1905/W-2025/W-2039
Expiration Date: **January 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com