

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011489-R8  
**DATE:** 03/06/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 02/10/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION   |
|---|---|
| <b>JELD-WEN</b><br><b>3737 Lakeport Boulevard</b><br><b>Klamath Falls, OR 97601</b> | <b>Series "Contours Steel (S-2500)</b><br><b>Wood Edge"</b><br><b>Steel Glazed Side Hinged Door</b><br><br>Configuration: X<br>Glazing: Insulating Glass (Tempered)<br>Frame: W-953mm(37.50") H-2052mm(80.75")<br>Panel: W-909mm(35.75") H-2013mm(79.25")<br>DLO: W-499mm(19.63") H-397mm(15.63") |

| SPECIFICATION     | PRODUCT RATING   |
|-------------------|--|
| <b>TAS 202-94</b> | <b>Design Pressure: 2634 Pa (55 psf)</b><br><b>Negative Design Pressure: 2634 Pa (55 psf)</b><br>Water Penetration Resistance Test Pressure: 396 Pa (8.25 psf) |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3857-1/A009078/W-1897/W-1905/W-2025/W-2039  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)