

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011492.03-R3
DATE: 03/13/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1
REVISION DATE: 03/19/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, VA 26104	Series "400/500/5400/5400S" Vinyl Single Hung Window w/Replacement Frame Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1016mm(40") H-1600mm(63") Sash: W-1267mm(37.88") H-775mm(30.50") DLO: W-902mm(35.50") H-718mm(28.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG40 1016 x 1600 (40 x 63)-H Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.90 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C5738.02-501-47/W-1962
Expiration Date: March 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.D.", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023