

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011501-R4
DATE: 03/21/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/06/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"MW Pro 800" Vinyl Clad Wood Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1864mm(73.4") H-2053mm(80.81") DLO: W-1741mm(68.56") H-1886mm(74.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG30 1864 x 2053 (73 x 81)-FW FW-LC30 1153 x 2051 (45 x 81) Design Pressure: ±1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15786-2/W-1988/W-2047
Expiration Date: April 30, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shirley", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023