

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011513-R2
DATE: 03/26/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 05/20/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	<p style="text-align: center;">Series “Pocket Sliding Glass Door”</p> <p style="text-align: center;">Aluminum Pocket Sliding Glass Door</p> <p style="text-align: center;">w/Impact Glazing</p> <p style="text-align: center;">Configuration: OXXXXX Sill Height: 4-1/4" Overall Glazing: Laminate-1/4" Heat Strengthened Glass/ 0.090" SentryGlas® Plus by DuPont/1/4" Heat Strengthened Glass</p> <p>Frame: W-8882mm(349.69") H-3632mm(143")</p> <p>Panel: W-1537mm(60.5") H-3545mm(139.56")</p>

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 TAS 201/202-203-94	<p style="text-align: center;">Class C-PG70 8882 x 3632 (350 x 143)-SD</p> <p style="text-align: center;">SD-C70 8882 x 3632 (350 x 143)</p> <p style="text-align: center;">Design Pressure: ±3352 Pa(±70 psf)</p> <p style="text-align: center;">Large Missile Impact Rated</p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 646 Pa(13.5 psf)</p>

Product Tested By: Fenestration Testing Laboratory, Inc.
 Report No: 09-625-6131/09-625-6108/W-2162
 Expiration Date: **March 31, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com