

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011548-R4
DATE: 04/23/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "960H" In-Swing Vinyl Side Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-902mm(35.5") H-2438mm(96") Panel: W-832mm(32.75") H-2340mm(92.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG25 902 x 2438 (36 x 96)-SHD SHD-LC25 902 x 2438 (36 x 96) Design Pressure: 1200 Pa (25 psf) Negative Design Pressure: 1200 Pa (25 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.75 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-3219_{E1AO}/310-3207_{E2AO}/W-2047
Expiration Date: **February 28, 2029**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023