

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011548.02-R4  
**DATE:** 04/23/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> 433 North Main Street Rocky Mount, VA 24151	<b>Series "960H" In-Swing</b> <b>Vinyl Side Hinged Door</b> <b>w/Fixed Sidelite</b>  Configuration: XO Glazing: Insulating Glass (Tempered)  Frame: W-1803mm(71") H-2438mm(96") Panel: W-857mm(33.75") H-2337mm(92")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	<b>Class LC-PG30 1803 x 2438 (71 x 96)-SHD</b> <b>SHD-LC30 1803 x 2438 (71 x 96)</b> <b>Design Pressure: 1440 Pa (30 psf)</b> <b>Negative Design Pressure: 1440 Pa (30 psf)</b> Water Penetration Resistance Test Pressure: 220 Pa (4.5 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-2769<sub>E1AO</sub>/310-3207<sub>E2AO</sub>/W-2047  
Expiration Date: **February 28, 2029**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023