

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011575-R4
DATE: 06/07/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Carriage House
CODE: 1008-1
REVISION DATE: 08/16/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Carriage House Door Company 1571 East Main Street Old Fort, NC 28762	Model "101" Swing Out Wood Impact Rated Garage Door w/Two Windows Configuration: XX Glazing: Monolithic- 1/4" Lexan Frame: W-3048mm(120.00") H-2438mm(96.00") Panel: W-1498mm(59.00") H-2413mm(95.00") DLO: W-1219mm(48.00") H-374mm(14.75")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-05/E1996-09 ANSI/DASMA 108-05/115-05	Design Pressure: 1915 Pa (40 psf) Negative Design Pressure: 2154 Pa (45 psf) Wind Zone 2-Missile Level D

Product Tested By: American Test Lab, Inc.
Report No: ATLNC 0121.01-13R
Expiration Date: **December 31, 2024**

Administrator's Signature: _____

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com