

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011577-R4
DATE: 06/10/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "200" Vinyl Single Hung Window w/Equal Lite Adaptors Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2134mm(84") Panel: W-1153mm(45.37") H-1038mm(40.87")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG45 1219 x 2134 (48 x 84)-H H-LC45 1219 x 2134 (48 x 84) Design Pressure: 2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 330 Pa(6.75 psf)

Product Tested By: National Certified Testing Laboratories
Report No: 310-3143/W-1881/W-2047
Expiration Date: **January 31, 2029**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com