

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011593.09-R9  
**DATE:** 10/28/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** ProVia Door  
**CODE:** 1212-1  
**REVISION DATE:** 08/18/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>ProVia LLC</b> <b>2150 State Route 39</b> <b>Sugarcreek, OH 44681</b></p>	<p style="text-align: center;"><b>Steel Out-Swing Glazed Double Side Hinged Doors w/Transom Impact Rated</b></p> <p style="text-align: center; font-size: small;">                     Configuration: O/XX                      Glazing: IG-Exterior-1/8" Tempered Glass/                      Interior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8"                      Annealed Glass or IG-Exterior-Laminate-1/8" Annealed Glass/0.090" Solutia                      Interlayer/1/8" Annealed Glass/Center-1/8" Tempered Glass/Interior-1/8"                      Tempered Glass/ IG-Exterior-1/8" Tempered Glass/Center-1/8" Tempered                      Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed                      Glass or IG-Exterior-1/8" Tempered Glass/Center-Decorative Inlay/Interior-                      Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass                      or IG-Exterior-1/8" Tempered Glass/Center-Wrought Iron Decorative                      Inlay/Interior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8"                      Annealed Glass                 </p> <p>Frame: W-1880mm(74.03") H-3284mm(129.28")</p> <p>Panel: W-908mm(35.75") H-2411mm(94.93")</p> <p>Transom: W-1880mm(74.03") H-805mm(31.69")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;"><b>ASTM E283-04(12)/E330-02(10)</b> <b>ASTM E1886-04/05/E1996-02/04/06/09/12a</b></p>	<p style="text-align: center;"><b>Design Pressure: 2633 Pa (55 psf)</b> <b>Wind Zone 3-Missile Level D</b></p>

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-110-15660-1/NCTL-110-15660-2/NCTL-110-15652-2/NCTL-110-15652-3/W-1635/W-2002/W-2024/W-2084/W-2104/W-2105/W-2170  
 Expiration Date: **December 31, 2028**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION &  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)