

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011595.01-R8  
**DATE:** 06/27/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** ProVia Door  
**CODE:** 1212-1  
**REVISION DATE:** 08/18/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ProVia LLC</b> <b>2150 State Route 39</b> <b>Sugarcreek, OH 44681</b>	<b>Fiberglass Out-Swing</b> <b>Opaque Side Hinged Door</b> <b>w/Sidelites</b>  Configuration: OXO  Sidelite Glazing: Insulating Glass (Tempered)  Frame: W-2598mm(102.32") H-2478mm(97.59") Panel: W-908mm(35.75") H-2411mm(94.94")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-02</b>	<b>Design Pressure: +45/-50 psf</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15660-1/NCTL-110-15650-4/NCTL-110-15651-4/W-1587/W-1978/W-2002/W-2103/W-2105/W-2170  
Expiration Date: **December 31, 2027**

Administrator's Signature: 

**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)