

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011632-R3
DATE: 08/14/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Solar
CODE: 872-1
REVISION DATE: 11/12/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Solar Innovations, Inc. 31 Roberts Road Pine Grove, PA 17963	Series "SI 5600 Pyramid Skylight" Impact Rated Skylight Window (Optional 2" Rafter Installations) Configuration: O Glazing: IG-5mm Tempered Glass/Laminate-3mm Annealed Glass/0.090"Dupont SentryGlas Plus Interlayer/3mm Annealed Glass or Monolithic-Laminate-3mm Annealed Glass/0.090"Dupont SentryGlas Plus Interlayer/3mm Annealed Glass Frame: W-2521mm (99.25") H-3753mm (147.75")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/E330-02(10)/E331-00(09)/ ASTM E1886-04/05/E1996-02/04/06/09/12a	Design Pressure: 3112 Pa (65 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 1436 Pa (30 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-110-15867-1
Expiration Date: May 31, 2031

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway
Hayes, VA 23072**

Tel: (804) 684-5124

Email: nami@namiinc.com