

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011633-R4
DATE: 08/14/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Solar
CODE: 872-1
REVISION DATE: 11/12/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Solar Innovations, Inc. 31 Roberts Road Pine Grove, PA 17963	“SI5900 Flat Welded Curb Skylight” Impact Rated Three (3)-Light Fixed Skylight Configuration: O Glazing: IG-5.6 mm Annealed Glass/Laminate-5mm Tempered Glass/0.090"DuPont SentryGlas Plus Interlayer/5mm Tempered Glass or IG 5mm Tempered Glass/Laminate-3mm Heat Strengthened Glass/0.060" DuPont SentryGlas Plus Interlayer/ 3mm Heat Strengthened Glass Frame: W-1829mm (72") H-1829mm (72")
SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/E330-02(10)/E331-00(09)/ ASTM E1886-04/05/E1996-02/04/06/09/12a	Design Pressure: 3840 Pa (80 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 1440 Pa (30 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-110-15873-1
Expiration Date: April 30, 2031

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023