

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011669-R6  
**DATE:** 09/16/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Mulia  
**CODE:** 1991-1  
**REVISION DATE:** 03/30/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Mulia Incorporated</b> <b>100 Business Center Drive # 12</b> <b>Ormond Beach, FL 32174</b>	<b>“LW Glass Block”</b> <b>Vinyl Fixed Window</b>  Configuration: O  Glazing: Nominal 3/8" Thick Annealed Pattern Glass  Frame: W-1438mm(56.62") H-1438mm(56.62") DLO: W-1368mm(53.87") H-1368mm(53.87")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG110 1438 x 1438 (57 x 57)-FW</b> <b>Design Pressure: 5280 Pa (110 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: C7461.01-401-44  
Expiration Date: **May 31, 2026**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
e-mail: [nami@namiinc.com](mailto:nami@namiinc.com)