

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011676.03-R3
DATE: 10/04/2013
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 07/13/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® "5400" Vinyl Sliding Glass Door w/Sill Riser Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-3658mm(144") H-2438mm(96") Panel: W-1229mm(48.38") H-2324mm(91.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 3658 x 2438 (144 x 96)-SD Design Pressure: 2394 Pa (50 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19psf)

Product Tested By: Architectural Testing, Inc.
Report No: C9930.03-550-44
Expiration Date: December 31, 2027

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
email: nami@namiinc.com