

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011691.01-R4
DATE: 10/24/2013
CERTIFICATION PROGRAM: Structural
COMPANY: KHPP Windows
CODE: 1954-1
REVISION DATE: 07/07/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
KHPP Windows and Doors 1136 Industrial Park Road Vandergrift, PA 15690	Series "Kingston Slider" Vinyl Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1600mm(63") H-1118mm (44") DLO: W-708mm(27.87") H-937mm (36.87")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG40 1600 x 1118 (63 x 44)-HS Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing Incorporated
Report No: C8998.01-501-44 (Specimen 2)
Expiration Date: **September 30, 2032**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. H. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com