

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011692-R4
DATE: 10/25/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Endura
CODE: 1353-1
REVISION DATE: 03/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Endura Products, Inc. 8817 West Market Street Colfax, NC 27235	"Masonite Glazed Fiberglass Door" (Large Missile) Fiberglass Inswing Glazed Double Door Configuration: XX Glazing: IG: 1/8" Tempered Glass/Laminate: 1/8" Annealed Glass/0.090" Solutia Safeflex PVB Interlayer/ 1/8" Annealed Glass Frame: W-1879mm(74.00") H-2485mm(97.87") Panel: W-908mm(35.75") H-2432mm(95.75") DLO: W-533mm(21.00") H-2006mm(79.00")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-05/09/E 1996-06/09 TAS 201/202/203-94	Design Pressure: 2154 Pa (45 psf) Negative Design Pressure: 2154 Pa (45 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3893-01/W-1780
Expiration Date: September 30, 2029

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023