

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011692.02-R4
DATE: 10/25/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Endura
CODE: 1353-1
REVISION DATE: 03/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Endura Products, Inc. 8817 West Market Street Colfax, NC 27235</p>	<p style="text-align: center;">“Masonite Glazed Fiberglass Door” (Large Missile) Fiberglass Inswing Glazed Double Door Configuration: XX Glazing: IG: 1/8" Tempered Glass/Laminate: 1/8" Annealed Glass/0.090" Solutia Safeflex PVB Interlayer/1/8" Annealed Glass Frame: W-1879mm(74.00") H-2079mm(81.87") Panel: W-908mm(35.75") H-2025mm(79.75") DLO: W-533mm(21.00") H-1574mm(62.00")</p>

SPECIFICATION	PRODUCT RATING
<p>ASTM E330-02 ASTM E1886-05/09/E 1996-06/09 TAS 201/202/203-94</p>	<p>Design Pressure: 2394 Pa (50 psf) Negative Design Pressure: 2394 Pa (50 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated</p>

Product Tested By: National Certified Testing Laboratories
 Report No: NCTL-210-3893-01/W-1779
 Expiration Date: **September 30, 2029**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com