

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011702.02-R3
DATE: 04/13/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Four Seasons
CODE: 1812-1
REVISION DATE: 04/06/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Four Seasons Solar Products, LLC 5005 Veterans Memorial Highway Holbrook, NY 11741	Series "4500" Vinyl Out-Swing French Side-Hinged Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2438mm(96") Panel: W-854mm(33.63") H-2375mm(93.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG35 1829 x 2438 (72 x 96)-SHD Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.
Report No: D4831.04-109-47/D1376.01-109-47
Expiration Date: **January 31, 2025**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com