NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011725.08-R3**
DATE:	**11/14/2013**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Wincore**
CODE:	**1640-1**
REVISION DATE:	**08/21/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC **250 Staunton Turnpike** **Parkersburg, VA 26104**	**Series "400/500"** **Vinyl Horizontal Sliding Window** Configuration: XX Glazing: Insulated Glass (Annealed) Frame: W-1600mm(63.00") H-1118mm(44.00") DLO: W-702mm(27.63") H-941mm(37.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class R-PG25 1600 x 1118 (63 x 44)-HS** **Design Pressure: 1197 Pa (25 psf)** **Negative Design Pressure: 1197 Pa (25 psf)** **Water Penetration Resistance Test Pressure: 287 Pa (6.00 psf)**

Product Tested By: Testing Evaluation Laboratory
Report No: TEL 02800807/W-1920
Expiration Date: **October 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com