

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011778-R3
DATE: 01/14/2014
CERTIFICATION PROGRAM: Structural
COMPANY: KHPP Windows
CODE: 1954-1
REVISION DATE: 07/07/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
KHPP Windows and Doors 1136 Industrial Park Road Vandergrift, PA 15690	Series "Huntington" Vinyl Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1600mm(63") H-1125mm (44") Sash: W-792mm(31.18") H-1020mm (40.16")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 1600 x 1125 (63 x 44)-HS Design Pressure: 2400 Pa (50.1 psf) Negative Design Pressure: 2400 Pa (50.1 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Exova
Report No: 12-06-M0422-3
Expiration Date: **December 31, 2032**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shirley", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com