NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011779-R3**
DATE:	**01/14/2014**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**KHPP Windows**
CODE:	**1954-1**
REVISION DATE:	**07/07/2022**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
KHPP Windows and Doors **1136 Industrial Park Road** **Vandergrift, PA 15690**	**Series "Quantum"** **Vinyl Double Hung Window** Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1020mm(40.16") H-1600mm (62.99") Sash: W-920mm(36.22") H-765mm (30.11")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class R-PG55 1020 x 1600 (40 x 63)-H** **Design Pressure: 2640 Pa (55.1 psf)** **Negative Design Pressure: 2640 Pa (55.1 psf)** **Water Penetration Resistance Test Pressure: 400 Pa (8.35 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Exova
Report No: 12-06-M0422-4
Expiration Date: **December 31, 2032**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com