

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011802-R4
DATE: 01/30/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Mariotti
CODE: 1891-1
REVISION DATE: 02/12/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Mariotti Building Products 1 Louis Industrial Drive Old Forge, PA 18518	Plastpro's In-Swing Glazed Fiberglass Double Doors w/Composite Jamb Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1879mm(74") H-2082mm(82") Panel: W-908mm(35.75") H-2012mm(79.25") DLO: W-536mm(21.13") H-1603mm(63.13") STP: Pos+48.0 psf Neg-58.0 psf

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/02 Federal Register Manufactured Home Construction & Safety Standards 3280.405	Federal Manufactured Housing-Passed Wind Zone II

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL-01390854
Expiration Date: December 31, 2025

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com