NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011802-R5**
DATE:	**01/30/2014**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Mariotti**
CODE:	**1891-1**
REVISION DATE:	**12/18/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Mariotti Building Products **1 Louis Industrial Drive** **Old Forge, PA 18518**	**Plastpro's In-Swing Glazed** **Fiberglass Double Doors** **w/Composite Jambs** Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1879mm(74") H-2082mm(82") Panel: W-908mm(35.75") H-2012mm(79.25") DLO: W-536mm(21.13") H-1603mm(63.13") STP: Pos+48.0 psf Neg-58.0 psf

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/02/12 **Federal Register Manufactured Home Construction & Safety Standards 3280.405**	**Federal Manufactured Housing-Passed Wind Zone II**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL-01390854/W-2143
Expiration Date: **December 31, 2026**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com