

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011803-R4
DATE: 01/30/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Mariotti
CODE: 1891-1
REVISION DATE: 02/12/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Mariotti Building Products 1 Louis Industrial Drive Old Forge, PA 18518	Plastpro's In-Swing Glazed Fiberglass Door w/Composite Jambs & Sidelite Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-1892mm(74.5") H-2082mm(82") Panel: W-908mm(35.75") H-2012mm(79.25") DLO: W-536mm(21.13") H-1603mm(63.13") STP: Pos+58.0 psf Neg-58.0 psf

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/02 Federal Register Manufactured Home Construction & Safety Standards 3280.405	Federal Manufactured Housing-Passed Wind Zone III

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL-01390855
Expiration Date: December 31, 2025

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S.M.', is written over the signature line.

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com