

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011803-R5  
**DATE:** 01/30/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Mariotti  
**CODE:** 1891-1  
**REVISION DATE:** 12/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Mariotti Building Products</b> <b>1 Louis Industrial Drive</b> <b>Old Forge, PA 18518</b>	<b>Plastpro's In-Swing Glazed</b> <b>Fiberglass Door</b> <b>w/Composite Jambs &amp; Sidelite</b>  Configuration: OX Glazing: Insulating Glass (Tempered)  Frame: W-1892mm(74.5") H-2082mm(82") Panel: W-908mm(35.75") H-2012mm(79.25") DLO: W-536mm(21.13") H-1603mm(63.13") STP: Pos+58.0 psf Neg-58.0 psf

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95/02/12</b> <b>Federal Register Manufactured Home</b> <b>Construction &amp; Safety Standards 3280.405</b>	<b>Federal Manufactured Housing-Passed</b> <b>Wind Zone III</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL-01390855/W-2143  
Expiration Date: December 31, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'M.D.', is written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023