## **NOTICE OF PRODUCT CERTIFICATION =**



**CERTIFICATION NO: NI011826-R3** 

**DATE:** 02/05/2014

**CERTIFICATION PROGRAM: Structural** 

**COMPANY:** Milliken

**CODE:** 997-1

**REVISION DATE: 11/21/2022** 

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Milliken Millwork, Inc.	Plastpro's In-Swing Flush Glazed
172 Plummer Road	Fiberglass Door
Sidman, PA 15955	w/Composite Jambs & Sidelites
	Configuration: OXO Glazing: Insulating Glass (Tempered)
	Frame: W-1739mm(68.50") H-2082mm(82.00")
	Panel: W-908mm(35.75") H-2012mm(79.25")
	DLO: W-666mm(26.25") H-1676mm(66.00")
	STP: Pos+46.0 psf Neg-58.0 psf

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-02 Federal Register Manufactured Home Construction & Safety Standards 3280.405	Federal Manufactured Housing-Passed Wind Zone I

Product Tested By: Testing Evaluation Laboratories, Inc.

Report No: TEL-01390857-R1 Expiration Date: **December 31, 2024** 

Administrator's Signature:

## NATIONAL ACCREDITATION AND

MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124
Email: nami@namiinc.com