

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011834-R3
DATE: 02/05/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Milliken
CODE: 997-1
REVISION DATE: 11/21/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Milliken Millwork, Inc. 172 Plummer Road Sidman, PA 15955 | Plastpro's In-Swing Glazed Steel Double Doors w/Composite Jambs Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1879mm(74.00") H-2082mm(82.00") Panel: W-908mm(35.75") H-2012mm(79.25") DLO: W-536mm(21.13") H-1603mm(63.13") STP: Pos+38.0 psf Neg-38.0 psf |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| AAMA 1702.2-02 Federal Register Manufactured Home Construction & Safety Standards 3280.405 | Federal Manufactured Housing-Passed Wind Zone I |

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL-01390850-R1
Expiration Date: December 31, 2024

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com