

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011917-R19  
**DATE:** 03/25/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 09/25/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>JELD-WEN</b><br><b>3737 Lakeport Boulevard</b><br><b>Klamath Falls, OR 97601</b> | <b>JELD-WEN “Design Pro/Smooth Pro Impact<br/>Approved/Studio” Fiberglass Glazed<br/>In-Swing or Out-Swing Side-Hinged Doors</b><br><br>Configuration: XX<br>Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed<br>Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass<br><br>IS Frame: W-1879mm(74.00") H-2081mm(81.93")<br>OS Frame: W-1879mm(74.00") H-2081mm(81.25")<br>Panel: W-908mm(35.75") H-2012mm(79.25")<br>DLO: W-606mm(23.87") H-1587mm(62.50") |

| SPECIFICATION  | PRODUCT RATING  |
|--|---|
| <b>ASTM E283-04/E330-02</b><br><b>TAS 202-94</b><br><b>ASTM E1886-05/E1996-06</b><br><b>AAMA 1304-02</b> | <b>Design Pressure: +50/-50 psf</b><br><b>Wind Zone 3 - Missile Level D</b><br>Qualifies Configurations: XX |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3918-01/NCTL-210-3924-02/SJW2013-234/SJW2013-235/SJW2013-251/SJW2013-252/SJW2013-253/NCTL-210-3924-01/ NCTL-210-3925-03/SJW2014-032/NCTL-210-3930-01/NCTL-210-3930-02/SJW2014-069/SJW2014-079/SJW2013-238/W-1669/W-1705/W-1783/W-1799/W-1861/W-1899/W-1904/W-1936/W-1943/W-1991/W-2005/W-2023/W-2039/W-2172

Expiration Date: **March 30, 2032**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/3/0/2023